

20:44:22:07. Residential heating plant disconnect. Heating plant installations that include auxiliary motor-operated equipment rated 25 amps or less require a disconnect at the unit.

Source: SL 1975, ch 16, § 1; 12 SDR 151, 12 SDR 155, effective July 1, 1986; transferred from § 20:44:05:07, August 12, 1994; 29 SDR 87, effective December 24, 2002; 43 SDR 181, effective July 10, 2017.

General Authority: SDCL 36-16-12.

Law Implemented: SDCL 36-16-12.

Note: Also see Article 424 of the **National Electrical Code**.

ARCHIVED