

20:44:22:27. Residential housing units moved to new locations. Single, modular, or multifamily residential units moved from one location to another must have at least a 100-ampere service at the new location and must meet the ground fault circuit interrupter protection, tamper resistant receptacle protection, and arc-fault circuit interrupter protection requirements of the **National Electrical Code**, Article:

- (1) 210.8 - ground fault circuit interrupter protection;
- (2) 210.12 - arc fault circuit interrupt protection;
- (3) 406.12 - tamper resistant receptacles;
- (4) 210.63 - receptacle within 25 feet of the heating and ac equipment; and
- (5) 406.9 - in use covers.

Source: 19 SDR 155, effective April 14, 1993; 20 SDR 222, effective July 6, 1994; transferred from § 20:44:05:32, August 12, 1994; 23 SDR 2, effective July 16, 1996; 29 SDR 87, effective December 24, 2002; 40 SDR 198, effective May 28, 2014; 43 SDR 181, effective July 10, 2017.

General Authority: SDCL 36-16-12.

Law Implemented: SDCL 36-16-27.