

**74:04:01:03. Required minimum fluoride levels -- Reduction of natural excessive levels.** If the average natural fluoride ion content of the water from any source for a municipal water supply is less than 0.9 mg/l, equipment must be provided and operated to adjust the fluoride ion concentration in the range of 0.9 mg/l to 1.7 mg/l, with an optimum level of 1.2 mg/l. Those municipal water supplies with average natural fluoride ion concentrations in excess of 1.7 mg/l must consult the department of environment and natural resources prior to initiating procedures for reducing the fluoride ion content to an optimum amount.

**Source:** SL 1975, ch 16, § 1; transferred from § 34:07:01:03. effective July 1, 1979; 13 SDR 129, 13 SDR 141, effective July 1, 1987.

**General Authority:** SDCL 34-24A-2.

**Law Implemented:** SDCL 34-24A-1, 34-24A-2, 34-24A-3.