

74:04:01:05. Daily testing required. Testing equipment shall be available for determining the fluoride content at each installation. The fluoride content shall be determined each day on a representative sample of fluoridated water. A variance to this requirement may be allowed by the secretary upon request and submission of evidence that other testing procedures are satisfactory.

Source: SL 1975, ch 16, § 1; transferred from § 34:07:01:05, effective July 1, 1979; 13 SDR 129, 13 SDR 141, effective July 1, 1987.

General Authority: SDCL 34-24A-2.

Law Implemented: SDCL 34-24A-1, 34-24A-2, 34-24A-3.

ARCHIVED