

74:04:01:07. Daily records required. Daily records of the fluoride content of the distribution system shall be maintained by the water system owners or their representatives. These records shall show the amount of fluoride chemical feed to the system, fluoride test results, amount of water pumped, and any other pertinent information required by the department of environment and natural resources. These records shall be available for review by the secretary.

Source: SL 1975, ch 16, § 1; transferred from § 34:07:01:07, effective July 1, 1979; 13 SDR 129, 13 SDR 141, effective July 1, 1987.

General Authority: SDCL 34-24A-2.

Law Implemented: SDCL 34-24A-1, 34-24A-2, 34-24A-3.

ARCHIVED