

61:15:07:03. Portable fire extinguishers. Portable fire extinguishers must be provided in each school occupancy and shall be inspected and maintained in accordance with NFPA 10, "Standards for Portable Fire Extinguishers," 2009 edition. Vaporizing liquid extinguishers containing carbon tetrachloride or chlorobromomethane may not be installed or used in any location for fire protection. Soda-acid, foam, loaded stream, antifreeze, and water fire extinguishers of the inverting type may not be recharged or placed in service for fire protection. Portable extinguishers shall be installed near food-processing equipment.

Source: 18 SDR 107, effective January 1, 1992; 23 SDR 32, effective September 11, 1996; 27 SDR 75, effective February 7, 2001; 33 SDR 113, effective January 2, 2007; 37 SDR 235, effective June 28, 2011.

General Authority: SDCL 13-25-2.

Law Implemented: SDCL 13-25-3, 13-25-4.

Reference: NFPA 10, "Standards For Portable Fire Extinguishers," 2007 edition, National Fire Protection Association. Copies may be obtained from the National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, Massachusetts 02269-9101; \$36.45 for members and \$40.50 for nonmembers.