

**61:15:07:16. Exit illumination.** Exit illumination shall be provided and maintained in accordance with the **International Building Code**, 2009 edition. Exits shall be illuminated as required by the **International Building Code** if the building or structure is occupied. Equipment providing emergency power for exit illumination and exit signs shall be maintained in an operable condition.

**Source:** 18 SDR 107, effective January 1, 1992; 23 SDR 32, effective September 11, 1996; 27 SDR 75, effective February 7, 2001; 33 SDR 113, effective January 2, 2007; 37 SDR 235, effective June 28, 2011.

**General Authority:** SDCL 13-25-2.

**Law Implemented:** SDCL 13-25-3, 13-25-4.

**Reference:** **International Building Code**, 2009 edition, International Code Council. Copies may be obtained from the International Code Council, 4051 West Flossmoor Road, Country Club Hills, IL 60478-5771; \$93.50 for members and \$124.50 for nonmembers. Telephone: 1-888-422-7233.

ARCHIVED