

**20:44:22:27. Residential housing units moved to new locations.** Single, modular, or multifamily residential units moved from one location to another must have at least a 100-ampere service at the new location and must meet the ground fault circuit interrupter protection, tamper resistant receptacle protection, and arc-fault circuit interrupter protection requirements of the **National Electrical Code**, Article 406-12, 210-8 and 210-12.

**Source:** 19 SDR 155, effective April 14, 1993; 20 SDR 222, effective July 6, 1994; transferred from § 20:44:05:32, August 12, 1994; 23 SDR 2, effective July 16, 1996; 29 SDR 87, effective December 24, 2002; 40 SDR 198, effective May 28, 2014.

**General Authority:** SDCL 36-16-12.

**Law Implemented:** SDCL 36-16-27.

ARCHIVED